



MINIMUM WIDTH OF CUT = 30'-0"

**SPECIFICATIONS FOR EASEMENT
CLEARING - PRIMARY
DISTRIBUTION LINES**

FILENAME: DSO2_** (*)

REV. DATE:	REV.
STD. #:	* _ *

DISTRIBUTION STANDARDS

LINE CLEARING SPECIFICATIONS



A FORTIS COMPANY

BELIZE ELECTRICITY LTD

2 1/2 Mls. Northern Highway
Belize City, Belize

APP. BY:	APP. DATE: 27 MAY 2009	DRAWN BY: B.SALINAS	SCALE: N.T.S.	SHEET #: SH 2 OF 2
----------	---------------------------	------------------------	------------------	-----------------------