



BELIZE ELECTRICITY LIMITED

2½ Miles Philip Goldson Highway | P.O. Box 327 | Belize City, Belize
Corporate: +501.227.0954 | Customer Care: 0.800.235.2273 | Fax: +501.223.0891

November 3, 2025

BEL Restores Power to San Pedro Following Power Interruption Caused by Hardware Fault on 34.5 kV Sub-Transmission Line

Belize Electricity Limited (BEL) informs our Customers of an unplanned power outage that affected Customers in San Pedro from **6:23 p.m. to 10:25 p.m. on Sunday, November 2, 2025**. The outage was caused by a hardware fault on the overhead portion of the 34.5 kV sub-transmission line that supplies power to the island.

The sub-transmission line that connects San Pedro to the national grid consists of three portions: the submarine cable interconnection from Maskall to San Pedro, an underground portion on the island, and an overhead portion on the island connecting to the San Pedro Substation.

The San Pedro Gas Turbine supplies power through the same sub-transmission line, which meant we could not use it to temporarily supply power to the island while our teams worked on repairs.

Furthermore, our teams encountered inclement weather conditions while conducting repairs, which caused unforeseen delays to the restoration process.

We thank our San Pedro team and all staff who responded swiftly, regardless of the weather conditions, to ensure that power was restored as quickly and as safely as possible.

BEL thanks our Customers in San Pedro for their patience and understanding as we continue working to deliver safe, reliable, and sustainable energy services to you.

-End-